

**ADDENDUM NO. 1**

Belohlavy Estates Lift Station and Force Main  
Crete, Nebraska  
September 17, 2020

Project Manual

The Project Manual for the Belohlavy Estates lift station and force main in Crete, Nebraska dated July 1, 2020 is hereby revised as follows:

Delete paragraph 7.8.2 in its entirety and replace it with the following paragraph:

7.8.2 - Schedule

Contractor to furnish and install submersible pumps and motors according to the following schedule:

Provide two pumps each with a pumping capacity of 90 gpm when pumping against a total dynamic head of 44.5 feet. Motors to be 5 HP maximum, 208 V, 3-phase, 60-cycle. Pumps shall be HOMA, Model GRP 34/3 FM or approved equal.

The previously specified model of ABS pumps are not approved for this project.

**END OF ADDENDUM NO. 1**

